





# MINISTRY OF WATER & SANITATION AND IRRIGATION UPPER TANA NATURAL RESOURCES MANAGEMENT PROJECT (UTanrmp)

P.O. Box 996-60100 EMBU Tel: 068 22 31376 E-mail: <u>utanrmp@gmail.com</u> <u>info@utanrmp.or.ke</u> <u>www.utanrmp.or.ke</u>

16th March 2020

**DEAR ALL** 

**RE: ADDENDUM NO 2 FOR: -**

# SUPPLY AND DELIVERY OF PIPES AND FITTINGS FOR VARIOUS WATER PROJECTS IN PROJECT AREA COUNTIES TENDER NO: MWSI/UTaNRMP/ICB/001/2019-20

Following the request for clarification from some tenderers, the following are the responses and clarifications to the issues raised in the tender document:

#### Lot (2)(C)- Tharaka Nithi: G.I pipes and fittings

Item	Description	Clarification sought	Response/Clarification
2.5	20mm diameter sprinkler of	Kindly clarify- is this	The sprinkler is double nozzel
	nozzle size 3.6mm x 2.1 bar	double nozzle sprinkler	sprinkler
	complete with valve sockets	and what should be	
		included	
2.15	20mm diameter HDPE saddle	Kindly clarify what size of	14 threads per inch
	clamp with female thread	thread	
2.18	20 mm diameter male	Kindly clarify what size of	14 threads per inch
	threaded adaptor coupler	thread	
	with BSP taper threaded		
	(HDPE)		
2.21	20*20 mm diameter male	Kindly clarify –is this a	This is a socket (HDPE)
	adaptor (HDPE)	male adaptor or connector	
3.32	20mm diameter sprinkler	Kindly clarify	20 mm G.I pipe 1m length
	tripod stand 1m long		threaded both sides supported
			by R6 1m tripod stand.
2.8	200mm diameter GI to VJ	Is this a stepped V.J	This is stepped V.J coupling
	adaptor	Coupling or flanged	
		adaptor	
2.10	63mm diameter barrel nipple	Diameter 63mm means a	63mm is approximately equal
		different size in G.I.	to 21/2"nipple
		Kindly let us know what	
		size you are asking for, is	
2.16		it 2" or 21/2 "	FRI : : 01/02
2.12	90mm GI socket	Does this mean a 3" socket	This is a 31/2" socket

Meru cou	nty lot 1(a)		
Item	DESCRIPTION	CLARIFICATION SOUGHT	RESPONSE/CLARIFICATION
1.36	20MM DIAMETER PN 12.5 PVC PIPE	Under KEBS standards KSO6-149 PART 2:2000 which was replaced by KS-1452- 2:2009 THE MINIMUM STANDARD IS PN16	CHANGE '20MM DIAMETER PN 12.5 DAIMETER PVC PIPE 'TO '20MM DAIMETER PVC PIPE PN 16 '
3.39	20 diameter Upvc PN 10 hydrant feeders	Kindly advice what should be included in the hydrant feeders	Change '20MM DAIMETER uPVC PIPE PN 10 hydrant feeders' to 20MM DAIMETER uPVC PIPE PN 16
	LOT (2)(a) G.I PIPES AND FITTINGS		
2.38	150 mm X80 Saddle Clamp	Kindly advice –are this	These are G.I saddle clamps
2.39	150mmX25 saddle clamp	saddle clamps of steel	•
2.4	110mm X25mm saddle clamp	or PE or PP	
2.41	110mm X 50 mm saddle clamp		
2.42	75mm X50 saddle clamp		
	Lot 3(a) Air valves and sectional valves	Kindly advise –what to be included in the	The connecting sockets to 250mm pipeline, respective tees and 50mm
3.01	250mm diameter air valve complete with accessories	accessories	Gate valve
3.02	200mm diameter air valve complete with accessories		
3.03	100 mm air valve complete with accessories		
3.1	150mm dia valve socket	150mm valve sockets are not available in plastic – can we quote for steel threaded and adaptor	These are G.I sockets
1.49	200mm diameter VJ adopter	Does this mean a flanged adaptor or a VJ Coupling?	This is a flanged adopter
2.4	250mm diameter class B GI Pipe with bell mouth	Is this a full length pipe that you are referring to?	It's a full length of 6 metres
2.6	200mm diameter GI flanged	No further information has been given on this. Whether single flanged or double flanged and specific length	6m length G.I pipe flanged both ends
2.11,2.12, 2.13, 2.14		Is it flanged ,plain end, or threaded ?what length is required	These are 6 meters G.I pipes flanged both ends

## Embu County lot(1)b

Item	Description	Clarification sought	Response/Clarification
1.08	20mm diameter	Under KEBS standards KS-	Change '20mm diameter *80m
	*80m long PN6	149 apart 2:2000 which was	long PN6 Upvc' to '20mm
	UPVC	replaced by KS -1452-2 2009	diameter UPVC' pipes 6 m length
		the minimum standard is	PN16'
		PN16	
1.1	315mmX160 mm	Can we quote for steel	Quote as per the tender document
	diameter reducer	socketed fittings	or equivalent

### LOT 1 (c) –Tharaka Nithi: UPVC PIPES AND FIITINGS

Item	Description	Clarification sought	Response/Clarification
1.1	25mm diameter UPVC	Under KEBS standards KS-	Change '25 mm diameter PN 10
	pipe PN 10	149 apart 2:2000 which was	U PVC pipes ' to '25mm
		replaced by KS -1452-2	diameter UPVC' pipes PN 12.5'
		2009 the minimum standard	
		is PN16	
1.22	20mm diameter HDPE	Kindly clarify the PN rating	Change '20 mm diameter HDPE
	pipe	and length of pipe	pipe' to '20mm diameter HDPE
			pipes 6M length PN 16'

#### NYERI COUNTY SUMMARY Lot (2) d

Item	Description	Clarification	Response/Clarification
		sought	
2	250mm diameter GI class B pipes	Kindly clarify	The clamps are saddle
	with clamps	what type of	clamps
		clamps	
2.4	150mm diameter G.I Pipes	Kindly clarify	Medium class is class 'B'
	medium grade with clamps	medium grade is it	and the clamp is saddle
		class B and what	clamp
		type of clamps	
2.5	100mm dia GI pipe, length 1.5 M	K and what type	100mm dia GI pipe, length
	with clamps	of clamps and	1.5 M with saddle clamps
		clarify –what class	class B
		of pipe	
2.13	225mm x 50mm saddle clamps	What does this	225mm x 50mm saddle
	with a nipple to fit a valve –	exactly mean?	clamps with a nipple to fit a
	double flanged GI pipe	What is the size of	50mm gate valve –double
		the nipple? What	flanged GI pipe. The two
		does the double	pipes joined by the saddle
		flanged G.I pipe	clamp are flanged on both
		mean?	ends
2.14	225mm x 75mm saddle clamp	Kindly clarify	The nipple should fit 50mm
	with a nipple to fit a gate valve –		gate valve. The two pipes
	double flanged GI pipe		joined by the saddle clamp
			are flanged on both ends
1.12,1.13	280mm X250mm diameter	Does this mean a	This is a stepped coupling

	GI/UPVC Adaptors,	flanged adaptor,	joining GI and uPVC pipe
		taper, stepped	
		coupling	
2.18	200mm diameter GI pipe	Kindly provide	Please revise as follows for
	medium grade one end plain, one	drawing for this, if	easier understanding
	end perforated with 20 mm	available for better	'200mm diameter GI pipe
	diameter holes at 200mm c/c pipe	understanding.	of 6mters length, class
	mouth capped 14 gauge Ms	There is no length	'B',one end plain, one end
	plates perforated with holes of	given	perforated with 20 mm
	the same size and aluminium		diameter holes at 200mm
	coated		length all round c/c, pipe
			mouth capped 14 gauge
			MS aluminum coated
			plates perforated with holes
			of 20mm diameter.'

#### KIRINYAGA 2(e)

Item	Description	Clarification sought	Response/Clarification
2.43	100mm X50mmX40mm diameter	Kindly provide a	This is a normal water
	fabricated Y tee flanged on 100 mm	drawing for this, for	divider G.I with
	diameter pipe	avoidance of	respective reducing
		misinterpretation	sockets.

#### **GENERAL**

Item	Description	Clarification sought	Response/Clarification
	25mm service meters complete with	Kindly clarify	Quote as per the tender
	accessories	whether it 25 mm	document
		equivalent to 1 inch or	
		20mm equivalent to 3/4	
		inch	

Bidders are further informed that the tender has 15No lots as follows:-

Line Item	Description of Goods	
N°		
Lot 1 (a)	uPVC pipes and fittings for Meru County	
Lot 1 (b)	uPVC pipes and fittings for Embu County	
Lot 1 (c).	uPVC pipes and fittings for Tharaka Nithi County	
Lot 1 (d).	uPVC pipes and fittings for Nyeri County	
Lot 1 (e)	uPVC pipes and fittings for Kirinyaga County	
Lot 2 (a)	GI pipes and fittings for Meru County	
Lot 2 (b)	GI pipes and fittings for Embu County	
Lot 2 (c).	GI pipes and fittings for Tharaka Nithi County	
Lot 2 (d).	GI pipes and fittings for Nyeri County	
Lot 2 (e)	GI pipes and fittings for Kirinyaga County	

Lot 3 (a)	Air valves and sectonal valves for Meru County
Lot 3 (b)	Air valves and sectonal valves for Embu County
Lot 3 (c).	Air valves and sectonal valves for Tharaka Nithi
Lot 3 (d).	Air valves and sectonal valves for Nyeri County
Lot 3 (e)	Air valves and sectonal valves for Kirinyaga County

Bidders are **FREE** to quote for one (1), a combination of lots or all the lots as indicated above. However, once a bidder quotes for a lot, all the items in the lot must be quoted for.

Bidders are informed that this ADDENDUM is part of the tender documents and all other items and conditionalities in the tender remain the same.

PROJECT COORDINATOR.
UPPER TANA NATURAL RESOURCES MANAGEMENT PROJECT